

**ADDENDUM NUMBER  
112719**

**PANAMA CITY BEACH  
AQUATIC CENTER  
POOL LINER  
REPAIR PROJECT  
2020**

**CITY OF PANAMA CITY BEACH, FLORIDA**

November 27, 2019



## Addendum Number 112719

Dated November 27, 2019

### Panama City Beach Aquatic Center Pool Liner Repair Project 2020-

#### 1. New Proposal Form to Replace the Original-

Changes include: Project Completion changed from Sat March 21 to Tue March 24, 2020; A minimum of a (5) Year Warranty change in language and additional info required for the Project Price Breakdown.

#### 2. Dewatering System – Replace Item Part 1 M -

The High Water Mark in the Aquatic Center is estimated at approximately 6 feet. The Dewatering System must be priced at 100% as there are no guarantees the Dewatering System Well Point Header Location when the Pool was originally built is workable.

The Dewatering System may be set up on the Aquatic Center Grounds during the week of February 24<sup>th</sup>, 2020. The Contractor will be responsible for draining the pool with the Dewatering system turned “ON” beginning Friday February 28<sup>th</sup> at approximately 6:30pm.

The Project Officially Starts on Friday February 28<sup>th</sup>, 2020 and is still planned to be completed by Saturday March 21, 2020 with the pool filling back up beginning Sunday March 22<sup>nd</sup> and Monday March 23 with Tuesday March 24<sup>th</sup> as the day the Dewatering system is to be removed by 10am.

#### 3. Project Time Line – Replace Item Part 1 J -

As explained in the Dewatering System above, The Project officially begins on Friday February 28<sup>th</sup> at 6:30pm and Final Completion/Inspection Date with Water in the pool will be Tuesday March 24<sup>th</sup> at 10am. **If Job is not completed and facility back in the same condition as it was when project started there will be Liquated Damages of \$1,000.00 per day beginning on Tuesday March 24<sup>th</sup> at 10:01am.**

If a second day, Wednesday March 25<sup>th</sup> at 10:01am liquated damages would be \$2,000.00 and if a third day Thursday March 26<sup>th</sup> at 10:01am liquated damages would be \$3,000.00 and so on.

Prep Work, Installation of Dewatering System and Material drop off may occur beginning Monday February 24<sup>th</sup> with the understanding that the pool will still be in use until Friday February 28<sup>th</sup> at 6:30pm.

**Bad Weather Clause-** If it is determined by the City and the Contractor’s Project Supervisor that the weather is too dangerous to work in or that weather will cause issues to the project then the day will be cancelled and a completion day will be added at the end of the project. **A Bad Weather Form will need to be filled out, signed by the Project Supervisor, the Parks and Recreation Director and Notarized by a City Staff member at the Parks and Recreation office at 16200 Panama City Beach Parkway, Panama City Beach, FL 32413.**

**4. The Pool Liner Membrane – In Addition to the specifications of Part 1 D, E & F–**

**Add the following:** The Pool Liner Membrane must be a minimum of 60 mil thick, 81” wide. Preferred products are Myrtha Pool Liners or RenoSys Pool Liners with their specifications. Any other pool liners recommended for this project would have to be researched and must be comparable to Myrtha or RenoSys Pool Liners before accepting the bid proposal.

It is preferred for the Pool Liner to be Light Blue but White would be acceptable.

**5. Warranty – Replace Item Part 1 C & Attachment C.**

A Minimum of a (5) Year Warranty must be included on the Pool Liner and Pool Lane Markers.

If any part of the Pool Liner or Pool Lane Markers fail in any way which include but not limited to coming off the walls/floors, cracking, fading, etc, The Warranty will cover all costs involved with repairs, replacements, travel, shipping costs, etc. **No Exceptions.**

**A New Attachment C replaces the original.**

**6. Gutters & Lane Designation Numbers – Part 1 A 3 & 5**

Gutters do not have Liners. When Repairing the Pool, Repair all seams in the gutters to prevent leaks.

Lane Designation Numbers on the bottom of the pool have been **Eliminated** from this project.

**Addendum Approval – (Confirming all information is understood)**

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

\_\_\_\_\_  
Print Name

\_\_\_\_\_  
Title

# NEW PROPOSAL FORM

TO: City of Panama City Beach, Florida

SUBMITTED: \_\_\_\_\_, 2019.

## **Aquatic Center Pool Liner Repair Project 2020**

The Undersigned, as Bidder, hereby declares that they have examined the proposal specifications and informed themselves fully in regard to all conditions pertaining to the equipment to be supplied.

The Bidder proposes and agrees, if this proposal is accepted, to contract with the **City of Panama City Beach** for the lump sum price listed, to furnish all labor, materials and supplies to install free and clear the **Aquatic Center Pool Liner Repair Project 2020** in complete accord with the described and reasonably intended requirements of the Request for Proposals to the satisfaction of the City, with a definite understanding that no additional money will be allowed for any corrections or additions. Payment in full will be made to the Bidder within 30 days of delivery and completion of installation acceptable to the City. The Bidder further agrees to the Specifications of the Time Line and will **have the Project Completed by Tuesday, March 24, 2020 at 10am** with liquidated damages thereafter of **\$1,000.00** per day.

Purchase will be made under terms and conditions specified by City in its form of a Purchase Order. If a deposit is required, it must be specified below. Final payment, in readily available funds, will be made upon acceptance by the City of strictly conforming goods after delivery and install. Strict adherence to design and specifications issued by the City or subsequently accepted in writing by the City will be required.

**ADDENDUM ACKNOWLEDGMENT:** (Only if addendums have been provided). I, the undersigned bidder, hereby acknowledge receipt of the following addenda: Addendum No.\_\_\_\_ Addendum No.\_\_\_\_.

### **SUMMARY DESCRIPTION AND LUMP SUM PRICE:**

- Note:**
1. A Detailed description of the type of the Pool Liner and type of Lane Markers being installed. Please include a sample of each of the Pool Liner and Lane Markers being installed with this Proposal.
  2. A Specific Project Date Checklist is required with this Proposal.
  3. A Dewatering System Plan- Please include the Plan for the Dewatering System with this Bid Proposal.
  4. A minimum of a (5) year signed and dated Warranty for the Pool Liner and Lane Markers (Exhibit C) to be attached with the Bid.
  5. A Cashier's Check Bid Bond of 5% of the total project to be included with the Bid or a sealed, stamped and dated Bid Bond with a Power Attorney and all signatures (Exhibit D).

<b>Aquatic Center Pool Liner Project Costs – Broken down in 3 Projects:</b>	<b>Dewatering System</b>	<b>\$ _____</b>
	<b>Pool Liner/Lane Markers</b>	<b>\$ _____</b>
	<b>Labor &amp; Supplies</b>	<b>\$ _____</b>
	<b>TOTAL LUMP SUM</b>	<b>\$ _____</b>

Specify terms of any deposit or write "none required": \_\_\_\_\_.

**Name of SUPPLIER:** \_\_\_\_\_

**ADDRESS:** \_\_\_\_\_ **CITY:** \_\_\_\_\_ **STATE:** \_\_\_\_\_ **ZIP:** \_\_\_\_\_

**EMAIL ADDRESS:** \_\_\_\_\_ **PHONE:** \_\_\_\_\_

**References:** Please list 3 successful Pool Liner Projects using the products you are recommending:

Name	Location	Address or Email	Phone Number
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

**SIGNATURE –** (Confirming all information above is correct) \_\_\_\_\_

**Print Name:** \_\_\_\_\_ **and Print Title** \_\_\_\_\_

I agree to post a Payment Bond, Performance Bond and Insurance (Exhibit E, F & G) if awarded the job - Initial \_\_\_\_\_

# New Warranty Agreement

## Panama City Beach Aquatic Center Pool Liner Project 2020

I am certifying that Supplier Name \_\_\_\_\_  
is providing a minimum of (5) Year Warranty on the New Pool Liner and  
Lane Markers being installed.

If any part of the Pool Liner or Pool Lane Markers fail in any way which  
include but not limited to coming off the walls/floors, cracking, fading, etc,  
The Warranty will cover all costs involved with repairs, replacements, travel,  
shipping costs, etc.

**No Exceptions.**

Please attach any written warranty information from the supplier.

Signature \_\_\_\_\_

Print Name \_\_\_\_\_

Date \_\_\_\_\_