



CITY OF PANAMA CITY BEACH

August 3, 2021

ADDENDUM NO. 1

PCB21-21 ITB

SR30A (US98) Utilities Relocation

QUESTION

1. What are the pipe sizes and types for this project?

- a. The jon includes 12" PVC force main, 16" PVC water main, and 20" PVC reuse main.