



## CITY OF PANAMA CITY BEACH

May 15, 2023

### ADDENDUM NO. 2

### PCB23-35 ITB Conservation Park Classroom

#### **Bidder Questions and Responses:**

1. Please clarify the mechanical louver quantity. On the Architectural page A-202 it shows mechanical louver on the east elevation however on the mechanical page M-100 it shows the east elevation as having two wall caps.

**R1.** *Louver required as specified for the outside air intake. Wall caps for restroom exhaust fans are acceptable.*

2. Question 4 from Addendum 1 asked for a material specification for the stone veneer.

**R2.** *Original stone was sourced from North Florida Brick (formerly North Bay Brick) or Freeport, Florida. Contact Brian at (850)832-1945 or [briannfbrick@gmail.com](mailto:briannfbrick@gmail.com) for more information.*

3. Please verify the size of the base plate for the wood columns.

**R3.** *Base Plate design by delegated engineer based on final attachment required by manufacturer of heavy timber columns.*